

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Dated: 24/05/25

No.

It is certified that an inspection team headed by Ex. Mohit Kumar (A.E.)

(Name of Officers with designation) from UP Jal Nigam Agra PHED

inspected the D.S.B. Public School New Khilli Basauni, Bah, Agra

(Name & Address of the school) on 24/05/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. UPJN/AUR/25/05/282 dated 26/05/25

of Regional water testing laboratory Agra PHED Lab) certified that

the D.S.B. Public School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till Six month.

Signature with Seal: [Signature] 27/05/25
Name : Ex. Mohit Kumar
Designation : A.E. Kant
Name & Address of the Office/Department : PHED (ग्रामीण) अग्र

To The manager
D.S.B. Public School
(Name & Address of the Institution)

Omika
(chemist)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

[Signature]
Principal
D.S.B. Public School
New Khilli Basauni Bah, Agra

[Signature]
Manager
D.S.B. Public School
New Khilli, Basauni, Bah, Agra



Regional Water Testing Laboratory
Address: 4/4 Sanjay Palace U.P. JaiNigam(Rural) Agra, 282002



TEST REPORT

Report No:	UPJN/AGR/05/25/282	Issue Date:	26/05/2025	Page No	2
Customer Details					
Office Name and Address	Principal D.S.B. Public School New Khilli Basauni, Bah ,Agra				
Ref Letter No & Date					
	Basic details of sample				
District	Agra	Block	Bah		
		Village/city	Agra		
Gram Panchayat	---	Location	DSB Public school		
Water Source	Supply water	Sample No.	01		
Quantity of Sample	1 Lt.	Date of Collection	23/05/2025		
Receiving Date	23/05/2025	S. Collector	DINA NATH SINGH		
Sample Depositor	DINA NATH SINGH	Sampling Method	As per IS 17614: Part 1: 2021		
Analysis Start Date	24/05/2025	Analysis Completion Date:	25/05/2025		

Technical Data of Analysis

S.No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS, 10500-2012		Ref. Method of Analysis Joint testing(100-130)
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH (@ 25°C)	7.27	6-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Turbidity mg/L	1.52	1	5	IS 3025 (Pt 10):1984 (Nephelometric Method)
3	Total Dissolved Solid mg/L	116	500	2000	IS 3025 (Pt 16):1984 (Gravimetric Method)
4	Fluoride mg/L	.628	1	1.5	APHA 23 rd Edition 4500-F Method C (Electrode method) 2017
5	Total Hardness mg/L	28	200	600	IS 3025 (Part 21):2009(EDTA Method)
6	Total Alkalinity mg/L	52	200	600	IS 3025 (Part 23):1986 (Potentiometric method)
7	Chloride mg/L	36	250	1000	IS 3025 (Part 32):1988 (Argentometric method)
8	Iron mg/L	0.19	1	1	APHA 23 rd Edition 3500-Fe Method B (Phenanthroline Method) 2017
9	Sulphate mg/L	02	200	400	APHA 23 rd Edition 4500-SO4 Method E (Turbidity Method) 2017
10	Calcium mg/L	18	75	200	IS 3025 (Part 40):1991(EDTA Titrimetric Method)
11	Magnesium mg/L	2.43	30	100	IS 3025 (Part 46):1994(Volumetric Method)
12	Color (Hazen)	02	5	15	APHA 23 rd Edition Color 2120 B (Visual Comparison Method).
13	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (PART 08) 1984 (Qualitative Method)

Digitally signed by Dina Nath Singh
Date: 2025.06.18 15:49:49 +05:30
Reason: reason
Location: location

New Khilli Basauni, Bah, Agra

Dina Nath Singh
Manager
D.S.B. Public School
New Khilli, Basauni, Bah, Agra



Regional Water Testing Laboratory

Address: 4/4 Sanjay Palace U.P. JalNigam(Rural) Agra, 282002




TC-0960

4	Nitrate (mg/l)	NILL	45	45	APHA 24 Edition -4500 NO3 method B (UV Spectrophotometric method:2023)
---	----------------	------	----	----	------------------------------------------------------------------------

ite
This Certificate refers only to the particular sample(s) submitted for testing.
This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved
stract.
The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports.

Reviewed By


(Amita Devi)

Deputy Quality Manager)

(Sanjay Upman)



Authorized Signatory:


Testing Lab In charge

Laboratory Contact details
Email- ZlaupjnR@gmail.com
Mob. (8630905287)

Mob-9761093634

-----End of Report-----


Principal
D.S.B. Public School
New Khili Basauni Bah, Agra


Manager
D.S.B. Public School
New Khili, Basauni, Bah, Agra